



DEVELOPMENT SERVICES

Inspection Services Division
1330 Broadway, 2nd Floor
Oakland, CA 94612

CORRECTION NOTICE

Name _____

1727 17th St.
Job Location

Address _____

E9202384
Permit Number

City/State _____

7/17/92
Date

An inspection of the subject premises on the above date revealed the following corrections and/or fees are necessary, as they do not comply with the requirements of the Oakland Code.

- Section
- ① Provide fault current calculations
 - ② Provide 1 line diagram of circuits which will remain in use
 - ③ Correct illegal bootleg work, double-bussing, over fusing, conduits not strapped, etc.

1727 17th St.

These corrections are required to be made within ten (10) days after receipt of this notice.

If there are any questions, please contact:

PHONE: 273-3441-Building Inspection
273-3341-Electrical Inspection
273-3291-Plumbing Inspection
273-3291-Mechanical Inspection

Name

[Signature]

Title

PHONE: 273- _____

6
5
2
0
0
0