Department of Industrial Relations
Division of Occupational Safety and Health
ELEVATOR, RIDE, AND TRAMWAY UNIT
1515 Clay St., Suite 1306
Oakland, CA 94612
Phone (510) 622-3026
Fax (510) 622-3045
BayAreaElevator@dir.ca.gov



Friday, December 27, 2013

City of Oakland, Attn: Walter Butler 250 Frank Ogawa Plaza, Suite 1329 Oakland, CA. 94612

Re: 455 - 7th. St., Oakland #035811

Building Manager;

I am rejecting the Hydraulic Load Test results, copy enclosed, because of the items listed on the attached sheet. Please contact your elevator company to discuss your options.

Respectfully;

David Henderson

Acting Senior, Elevator Unit

State of California

Department of Industrial Relations
Division of Occupational Safety and Health
ELEN A TOR, RIDE, AND TRAMWAY UNIT
1515 Clay Street, Suite 1306
Caldand, CA 94612
Phone (510) 622-3026
Fax (510) 622-3045



Date: Responsible Party of Elevator No. 3581 To: Five Year Hydraulic Load Test Subject: The Division has the reviewed the five year hydraulic load test report dated 12/17/13The report is not in compliance as submitted and is being returned for the following reason(s): Capacity does not correspond with original job specifications. Rated car speed does not correspond with original job specifications. The rated speed shall be adjusted to be not greater than 110% of full load up speed. The full load down speed shall be adjusted to be not greater than 125% of rated speed. The full load down speed shall be adjusted to conform to the buffer stroke requirement. The relief valve is set at a pressure greater than 125% of the full load running pressure. The pressure relief valve is not sealed. Tag with proper information is not attached to the pumping unit. Static test failed. Pressure switch not tested. Incomplete form as noted on return form. Pit valve rating does not match the pressure of the system. Signature of Building Owner/Responsible Party is missing. New Load Test shall be witnessed by the Division. Elevator Company shown as performing test is not listed as certified to work in California. Other:

Should you have any questions about this report, you may call this office.

Sincerely

allen Rutherford

Department of Industrial Relations
Division of Occupational Safety and Health
ELEVATOR, RIDE, AND TRAMWAY UNIT

GROUP 2 FIVE YEAR HYDRAULIC LOAD TEST REPORT

To comply with the Elevator Safety Orders, 3071(j), this form shall be filled out and returned by the compliance date shown on the Preliminary Order. If repairs, adjustments or replacements are needed for code compliance, they are to be completed before returning this form. Submitting an incorrect report may cause another test to be required, witnessed by the Division, with additional fees. L.C. 7314

	· · · · · · · · · · · · · · · · · · ·
Elevator State Number 035811	Date of Test
Location of Elevator 455 7th Street	
Oakland City	94612 Zip
Elevator Rated Load as Shown on C	Crosshead Data Plate 2000
C 2 4 2013 Elevator Up Speed with Rated Load HIERT UNITS LAND OFFICE	d 22 Elevator Down Speed with Rated Load 42 Rated Car Speed Feet per Minute Buffer stroke in Inches 00 or less 1 1/2 01 to 150 2 1/2 51 to 200 4
Working Pressure 23	Relief Valve Pressure (125% max.) 400
Pit Shut off Valve Rating	OO MR Shut off Valve Rating 1000
91	
OSV Tripping Speed45	Outside Diameter of Ram 5.45
	Outside Diameter of Ram 5.45 Maximum Centrifugal Pump Pressure W/A
Relief Valve Sealed? Yes No Movement of Elevator with Rated	Maximum Centrifugal Pump Pressure
Relief Valve Sealed? Yes No Movement of Elevator with Rated	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable)
Relief Valve Sealed? Yes No No Movement of Elevator with Rated (NOTE: Movement greater than .250 inch Pressure Switch: Yes No CQCC Performing Test Dream Ri	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable) Derrational? Load Test Data: Tag Attached: Yes No.
Relief Valve Sealed? Yes No Movement of Elevator with Rated (NOTE: Movement greater than .250 inch Pressure Switch: Yes No CQCC Performing Test Dream Ri Co (707) 745	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable) Decrational? Load Test Data Tag Attached: Yes No. de Elevator #CC-07-012839 Expires: July 2, 2015 mpany Name, Certification Number and Expiration
Relief Valve Sealed? Yes No Movement of Elevator with Rated (NOTE: Movement greater than .250 inch Pressure Switch: Yes No CQCC Performing Test Dream Ri Co (707) 745	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable) Decrational? Load Test Data Tag Attached: Yes No. de Elevator #CC-07-012839 Expires: July 2, 2015 mpany Name, Certification Number and Expiration 5-1380 CC Telephone Number
Relief Valve Sealed? Yes No No Movement of Elevator with Rated (NOTE: Movement greater than .250 inches Pressure Switch: Yes No COCC Performing Test Dream Ricco (707) 745	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable) Derrational? Load Test Data Tag Attached: Yes No de Elevator #CC-07-012839 Expires: July 2, 2015 mpany Name, Certification Number and Expiration 1380 CC Telephone Number Verification by COCC of Current Responsible Party
Relief Valve Sealed? Yes No Movement of Elevator with Rated (NOTE: Movement greater than .250 inches Pressure Switch: Yes No Cocce Note: No Cocce (707) 745 CCCM Performing Test TENRY FAMEL	Maximum Centrifugal Pump Pressure Load in 15 Minutes without proper justification is unacceptable) Decrational? Load Test Data Tag Attached: Yes No. de Elevator #CC-07-012839 Expires: July 2, 2015 mpany Name, Certification Number and Expiration 5-1380 CC Telephone Number Verification by COCC of Current Responsible Party Arnel Garcia - City of Oakland Public Works Agency