

**From:** [Nicks, Johnny](#)  
**To:** [Patton, Kenneth](#)  
**Cc:** [Vicentina, Cathy](#)  
**Subject:** RE: Public Records Request # 9543  
**Date:** Wednesday, May 13, 2015 10:09:09 AM  
**Attachments:** [310 8th Street Sewer Leak.pdf](#)

---

Cathy,

Here is the information you requested concerning 310 8<sup>th</sup> Street. Staff was out it this location on two separate occasions; on both occasions staff notified the property manager that this was an internal issue. Staff found the City Main Sewer was clear and running normal. Staff made a dye test in the building at 320 8<sup>th</sup> street from the 5<sup>th</sup> floor and the dye showed in the **man hole** in front of 320 8<sup>th</sup> street. Staff noted no one is calming Responsibility for the Sewage going into the elevator shaft. Sewage was leaking into the elevator shaft but it's internal. The City Main Was Clear. If you have any other questions please give me a call.

Thanks!

**J.R. Nicks**

**Supervisor 1, Sewer Maintenance Division**

**Bureau of Infrastructure & Operations**

**City of Oakland | Public Works Agency | APWA Accredited Agency**

**7101 Edgewater Dr, Bldg 4 | Oakland, CA 9462**

[\(510\) 615-5941](tel:(510)615-5941) Phone | [\(510\) 615-5550](tel:(510)615-5550) Fax  
[jnicks@oaklandnet.com](mailto:jnicks@oaklandnet.com)

---

**From:** Patton, Kenneth  
**Sent:** Wednesday, May 13, 2015 9:39 AM  
**To:** Nicks, Johnny  
**Cc:** Vicentina, Cathy  
**Subject:** FW: Public Records Request # 9543  
**Importance:** High

Johnny,

Can you Supply Ms. Vicentina with this information. Thank you.

Kind Regards,

**Kenneth Patton**

Public works Supervisor II Bureau of Infrastucture and Operations  
City of Oakland | Waste Water Collections | APWA Accredited Agency  
(510) 615-5539 | 7101 Edgewater Dr, Bldg 4 | Oakland, CA 94621