



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

REED BROTHERS SECURITY/SECURITY CENTRAL INC.

4432 TELEGRAPH AVE

4432 Telegraph Ave.

OAKLAND CA 94609

Oakland, CA

94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 10/7/2016 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.


Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2014-33162



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

4430 TELEGRAPH AV #49

Oakland CA 94609

Pursuant to OMC Sec. 15.12, a Operational Permit inspection was conducted on 7/8/2012 at the site location which found the facility to be Approved with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency <i>Corrective Action</i>	Deficiency Status <i>Location</i>
--	--------------------------------------

CFC 3003.5.3

Compressed gas containers, cylinders and tanks shall be secured.

Permit Condition

CFC 1007.1

Exits, means of egress pathways, shall be maintained without obstruction at all times.

Permit Condition

T19.5.5 -567.1

Portable fire extinguishers shall be maintained in a fully charged operable condition, and kept in designated place.

Permit Condition

All cooking areas

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to kcatano@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2012-09166



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

ON TIME LIMOZINE

4430 TELEGRAPH AVE #121

4430 TELEGRAPH AVE # 121

OAKLAND CA 94609

OAKLAND CA

94609-2018

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 2/27/2013 at the site location which found the facility to be **Fac Closed** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.


Should you have any questions, please call (510) 238-3851 or send email to sta8A@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2012-03656



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

REED BROTHERS SECURITY/SECURITY CENTRAL INC.

4432 TELEGRAPH AVE

4432 Telegraph Ave.

OAKLAND CA 94609

Oakland, CA

94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 9/29/2014 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8b@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2012-02937



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

ON TIME LIMOZINE

4430 TELEGRAPH AVE # 121

OAKLAND CA

94609-2018

Facility / Site Location

4430 TELEGRAPH AVE #121

OAKLAND CA 94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 3/31/2011 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8b@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-44175



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

ON TIME LIMOZINE

4430 TELEGRAPH AVE # 121

OAKLAND CA

94609-2018

Facility / Site Location

4430 TELEGRAPH AVE #121

OAKLAND CA 94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 3/20/2012 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-36630



Report of Fire Inspection
Commercial Inspection



7496567 For Official Use Only

Start Time: _____ End Time: _____

O/C _____ BTL# _____

E/C # _____ TJT _____

Address: 4480 Telegraph Ave, Ste _____

Business Name: Reed Brothers

Contact Name: Randy Reed

Owner / Mgr Bus. Phone # 510 652-2477 Fax# _____

Inspection: ☒ 1st ☐ 2nd ☐ 3rd ☐ Other _____

Inspection Date: 09-23-14 Inspector (Print): D. Williams

Contact Made/Inspection Permission Granted: ☐ Yes ☐ No

2014 OCT 27 PM 12 23

GENERAL SAFETY REQUIREMENTS

	N/C	OK	N/A
CFC 505.1 Provide building address numbers plainly visible and legible from the street or road fronting the property.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.3 Keep dumpsters 5 feet from combustible walls, openings, and combustible roof eaves.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Reduce the amount of flammable or combustible liquids used for maintenance purposes for the operation of equipment to 10 gallons or less.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 3404.3.4.4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 315.2.3 Combustible not permitted in boiler rooms, mechanical rooms, or electrical equipment rooms.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Storage shall be maintained 2 ft. or more below the ceiling in non-sprinkled areas of the buildings or a minimum of 18" below sprinkler deflectors.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 315.2.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 315.2 Storage of combustible materials in buildings shall be orderly with storage separated from heating devices.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.1 Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 506.2 Fire Department key box (Knox box) is installed and keys are current.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 503.4 Fire access roads shall not be obstructed in any manner.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 703.1 #2 Repair, restore or replaced damaged, altered, or breached all penetrations to fire-resistive rated construction.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

EXITING SAFETY REQUIREMENTS

CFC 1001.2 Remove obstructions from exits, aisles, corridors, and stairways.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Locking devices shall be approved.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 703.2 Exit doors shall be maintained in operable condition, at all times.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.2 Exit doors shall swing in the direction of travel when occupant load exceeds 50 persons.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Provide sign "DOOR TO REMAIN UNLOCKED WHILE OCCUPIED" above main entrance.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1011.2 Provide illuminated (internal/external powered) exit signs when two or more exits are required.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1011.1 Exit signs shall be installed at required exits and where otherwise necessary to clearly indicate direction of egress.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1006.1 Provide illuminated means of egress whenever building is occupied.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1006.3 Provide/Service emergency egress illumination when two or more exits are required.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 1014.4.1 Minimum clear aisle width shall not be less than 36 inches.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

FIRE PROTECTION SYSTEMS

CFC 906.1 A minimum of one 2A:10B:C fire extinguisher present for each 3000 sq/ft, travel distance not to exceed 75 ft.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 906.2 Service fire extinguishers annually, or when gauge indicates service required.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 906.1 #2 Install a 40-B:C fire extinguisher within 30 feet of cooking equipment and a Class K fire extinguisher for deep fat fryers.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 907.20.1 Fire Alarm shall be maintained in operating condition.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
19 CCR § 904 Fire Suppression systems shall be in operating condition (Inspected/Service Qtrly; Recertified every 5 years).	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 903.4 Sprinkler systems with 20 heads or more shall be electronically supervised.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Commercial cooking equipment producing grease laden vapors shall be provided with an automatic fire extinguishing system.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 904.11	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 508.5.4 Fire hydrants and other fire protection equipment shall not be obstructed.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 904.11.6.4 Service automatic fire-extinguishing systems every 6 months, and after activation of the system.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

ELECTRICAL REQUIREMENTS

CFC 605.5 Extension cords and flexible cords shall not be used as a substitute for permanent wiring.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 605.5.3 Appliance cords maintained in good condition without splices, deterioration, or damage.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 605.3 Provide a minimum clearance of 30" wide, 36" deep, and 78" from face of electrical switchboards and panel boards.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 605.3.1 Clearly identify electrical rooms with signage and label all disconnecting means, feeder/branch circuits.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 605.6 Open junction boxes and open-wiring splices shall be provided with approved electrical outlet/switch covers.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

PERMITS

105.6.34 Obtain Public Assembly Permit from Fire Prevention	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
105.6.32 Obtain Open Flame Permit for Candles/Open flame in Public Assembly occupancies from Fire Prevention	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
105.6.22 Obtain Permit for High-Piled Storage	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

MISCELLANEOUS REQUIREMENTS

OMC 5.04.040 Valid City of Oakland Business Tax Certificate	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CCR 2729.1(a) Provide/Obtain a current Hazardous Materials Business Plan (HMBP)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

In accordance with the California Fire Code Section 104.5 you are hereby ordered to correct all violations marked N/C immediately upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties. An inspection to determine if you have complied with this order will be conducted on or about _____. An inspection fee will be invoiced at a later date in accordance with the City's Master Fee Schedule. If you have questions, contact the inspector above at phone number _____.

Date: 09/23/14 Owner/Mgr (Signature) [Signature] Owner/Mgr (Print) RANDY R. REED



Report of Fire Inspection
Residential Inspection



For Official Use Only

Start Time: 11:00 End Time: _____

O/C _____ BTL# _____

BLK # 1099 T/JT _____

Address: 4430 Telegraph Ste _____ Business Name: On Time Limousine

Contact Name: N/A Owner / Mgr _____ Bus. Phone # _____ Fax# _____

Inspection: ☒ 1st ☐ 2nd ☐ 3rd ☐ Other _____ Inspection Date: 2-26-13 Engine Co: 2548

Contact Made/Inspection Permission Granted: ☒ Yes ☐ No

GENERAL SAFETY REQUIREMENTS

	N/C	OK	N/A
CFC 505.1 Provide building address numbers plainly visible and legible from the street or road fronting the property.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.3 Keep dumpsters 5 feet from combustible walls, openings, and combustible roof eaves.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Reduce the amount of flammable or combustible liquids used for maintenance purposes for the operation of equipment to 10 gallons or less.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 3404.3.4.4			
CFC 315.2.3 Combustible not permitted in boiler rooms, mechanical rooms, or electrical equipment rooms.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Storage shall be maintained 2 ft. or more below the ceiling in non-sprinkled areas of the buildings or a minimum of 18" below sprinkler deflectors.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 315.2.1			
CFC 315.2 Storage of combustible materials in buildings shall be orderly with storage separated from heating devices.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.1 Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 506.2 Fire Department key box (Knox box) is installed and keys are current.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 503.4 Fire access roads shall not be obstructed in any manner.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 703.1 #2 Repair, restore or replaced damaged, altered, or breached all penetrations to fire-resistive rated construction.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EXITING SAFETY REQUIREMENTS

CFC 1001.2 Remove obstructions from exits, aisles, corridors, and stairways.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Locking devices shall be approved.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 703.2 Exit doors shall be maintained in operable condition, at all times.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.2 Exit doors shall swing in the direction of travel when occupant load exceeds 50 persons.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Provide sign "DOOR TO REMAIN UNLOCKED WHILE OCCUPIED" above main entrance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1011.2 Provide illuminated (internal/external powered) exit signs when two or more exits are required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1011.1 Exit signs shall be installed at required exits and where otherwise necessary to clearly indicate direction of egress.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1006.1 Provide illuminated means of egress whenever building is occupied.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1006.3 Provide/Service emergency egress illumination when two or more exits are required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FIRE PROTECTION SYSTEMS

CFC 906.1 A minimum of one 2A:10B:C fire extinguisher present for each 3000 sq/ft, travel distance not to exceed 75 ft.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 906.2 Service fire extinguishers annually, or when gauge indicates service required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 906.1 #2 Install a 40-B:C fire extinguisher within 30 feet of cooking equipment and a Class K fire extinguisher for deep fat fryers.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 907.20.1 Fire Alarm shall be maintained in operating condition.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19 CCR § 904 Fire Suppression systems shall be in operating condition (Inspected/Service Qtrly; Recertified every 5 years).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 903.4 Sprinkler systems with 20 heads or more shall be electronically supervised.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 904.11 Commercial cooking equipment producing grease laden vapors shall be provided with an automatic fire extinguishing system.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 508.5.4 Fire hydrants and other fire protection equipment shall not be obstructed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 904.11.6.4 Service automatic fire-extinguishing systems every 6 months, and after activation of the system.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ELECTRICAL REQUIREMENTS

CFC 605.5 Extension cords and flexible cords shall not be used as a substitute for permanent wiring.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.5.3 Appliance cords maintained in good condition without splices, deterioration, or damage.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.3 Provide a minimum clearance of 30" wide, 36" deep, and 78" from face of electrical switchboards and panel boards.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.3.1 Clearly identify electrical rooms with signage and label all disconnecting means, feeder/branch circuits.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.6 Open junction boxes and open-wiring splices shall be provided with approved electrical outlet/switch covers.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PERMITS

105.6.34 Obtain Public Assembly Permit from Fire Prevention	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
105.6.32 Obtain Open Flame Permit for Candles/Open flame in Public Assembly occupancies from Fire Prevention	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
105.6.16 Obtain Permit for Flammable/Combustible Liquid Storage/Use from Fire Prevention	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

MISCELLANEOUS REQUIREMENTS

OMC 5.04.040 Valid City of Oakland Business Tax Certificate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
P.O. Box only *	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

In accordance with the California Fire Code Section 104.5 you are hereby ordered to correct all violations marked N/C immediately upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties. An inspection to determine if you have complied with this order will be conducted on or about ____/____/____. If you have questions, contact the undersigned inspector at phone number _____.

Date: 2/26/13 Owner/Mgr _____ Inspector (Print) 4532 K. Cuneo



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

REED BROTHERS SECURITY/SECURITY CENTRAL INC.

4432 TELEGRAPH AVE

4432 Telegraph Ave.

OAKLAND CA 94609

Oakland, CA

94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 2/25/2012 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Deficiency Status

Corrective Action

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.


Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-79483



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

ON TIME LIMOZINE

4430 TELEGRAPH AVE #121

4430 TELEGRAPH AVE # 121

OAKLAND CA 94609

OAKLAND CA

94609-2018

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 3/31/2011 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.


Should you have any questions, please call (510) 238-3851 or send email to sta8b@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-44175



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

ON TIME LIMOZINE

4430 TELEGRAPH AVE #121

4430 TELEGRAPH AVE # 121

OAKLAND CA 94609

OAKLAND CA 94609-2018

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 3/20/2012 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-36630



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

REED BROTHERS SECURITY/SECURITY CENTRAL INC.

4432 TELEGRAPH AVE

4432 Telegraph Ave.

OAKLAND

CA 94609

Oakland, CA

94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 10/7/2016 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2014-33162



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

TAMARA THOMPSON

4430 TELEGRAPH AVE # 30

OAKLAND CA

94609-2018

Facility / Site Location

4432 TELEGRAPH AVE #30

OAKLAND

CA 94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 2/28/2012 at the site location which found the facility to be **Fac Closed** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.


Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-17055



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

4430 TELEGRAPH AV #49

Oakland CA 94609

Pursuant to OMC Sec. 15.12, a Operational Permit inspection was conducted on 7/8/2012 at the site location which found the facility to be **Approved** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency <i>Corrective Action</i>	Deficiency Status <i>Location</i>
CFC 3003.5.3 Compressed gas containers, cylinders and tanks shall be secured.	Permit Condition
CFC 1007.1 Exits, means of egress pathways, shall be maintained without obstruction at all times.	Permit Condition
T19.5.5 -567.1 Portable fire extinguishers shall be maintained in a fully charged operable condition, and kept in designated place.	Permit Condition <i>All cooking areas</i>

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to kcatano@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2012-09166



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

PROPERTY MAINTENANCE CONSULTANT

4432 TELEGRAPH AVE #140

4430 TELEGRAPH AVE # 140

OAKLAND CA 94609

OAKLAND CA

94609-2018

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 2/28/2012 at the site location which found the facility to be Fac Closed with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2011-02393



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Facility / Site Location

REED BROS SECURITY/SECURITY CENTRAL INC
4430 TELEGRAPH AVE
OAKLAND CA 94609

4430 TELEGRAPH AVE
OAKLAND CA 94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 2/23/2007 at the site location which found the facility to be **Compliant** with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2007-46393



Oakland Fire Department, Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste. 3341
Oakland, CA 94612-2032



(510) 238-3851
TTY (510) 238-6884

Report of Fire Inspection

Date 2/22/2017

Rent-A-Relic

RACS RELICS INC.

4444 TELEGRAPH AVE.

OAKLAND, CA

94609-2018

Facility / Site Location

4444 TELEGRAPH AVE

OAKLAND CA 94609

Pursuant to OMC Sec. 15.12, a Commercial inspection was conducted on 10/7/2016 at the site location which found the facility to be Blue Tag with City of Oakland fire regulations. In accordance with CFC 104.5 you are hereby ordered to immediately correct all deficiencies, listed below, upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties.

Deficiency

Corrective Action

Deficiency Status

Location

A reinspection will be conducted on or about . To avoid additional charges, all deficiencies noted above must be corrected prior to the reinspection. If any deficiency remains uncorrected during the reinspection, additional inspection fees and penalties will be charged.

Should you have any questions, please call (510) 238-3851 or send email to sta8c@oaklandnet.com

Sincerely,
Fire Inspection Services Unit
Oakland Fire Department

Inspection Ref # 2014-33163

Oakland Fire Department
Fire Prevention Bureau
250 Frank H. Ogawa Plaza, Ste 3341
Oakland, CA 94612
510-238-3851



Report of Fire Inspection Commercial Inspection

1012568



For Official Use Only

Start Time: _____ End Time: _____

O/C _____ BTL# _____

E/C # _____ TJT _____

Address: 4444 Telegraph Ave, Ste _____ Business Name: Racs Relics

Contact Name: TODD CONNORS Owner / Mgr 2014 OCT 21 09:11:23 Fax# _____

Inspection: ☒ 1st ☐ 2nd ☐ 3rd ☐ Other _____ Inspection Date: 09-23-14 Inspector (Print): D. Williams

Contact Made/Inspection Permission Granted: ☐ Yes ☐ No

GENERAL SAFETY REQUIREMENTS

	N/C	OK	N/A
CFC 505.1 Provide building address numbers plainly visible and legible from the street or road fronting the property.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.3 Keep dumpsters 5 feet from combustible walls, openings, and combustible roof eaves.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Reduce the amount of flammable or combustible liquids used for maintenance purposes for the operation of equipment to 10 gallons or less.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 3404.3.4.4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 315.2.3 Combustible not permitted in boiler rooms, mechanical rooms, or electrical equipment rooms.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Storage shall be maintained 2 ft. or more below the ceiling in non-sprinkled areas of the buildings or a minimum of 18" below sprinkler deflectors.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 315.2.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 315.2 Storage of combustible materials in buildings shall be orderly with storage separated from heating devices.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 304.3.1 Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 506.2 Fire Department key box (Knox box) is installed and keys are current.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 503.4 Fire access roads shall not be obstructed in any manner.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 703.1 #2 Repair, restore or replaced damaged, altered, or breached all penetrations to fire-resistive rated construction.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

EXITING SAFETY REQUIREMENTS

CFC 1001.2 Remove obstructions from exits, aisles, corridors, and stairways.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Locking devices shall be approved.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 703.2 Exit doors shall be maintained in operable condition, at all times.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.2 Exit doors shall swing in the direction of travel when occupant load exceeds 50 persons.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1008.1.9.3 Provide sign "DOOR TO REMAIN UNLOCKED WHILE OCCUPIED" above main entrance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1011.2 Provide illuminated (internal/external powered) exit signs when two or more exits are required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1011.1 Exit signs shall be installed at required exits and where otherwise necessary to clearly indicate direction of egress.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1006.1 Provide illuminated means of egress whenever building is occupied.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1006.3 Provide/Service emergency egress illumination when two or more exits are required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 1014.4.1 Minimum clear aisle width shall not be less than 36 inches.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FIRE PROTECTION SYSTEMS

CFC 906.1 A minimum of one 2A:10B:C fire extinguisher present for each 3000 sq/ft, travel distance not to exceed 75 ft.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 906.2 Service fire extinguishers annually, or when gauge indicates service required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 906.1 #2 Install a 40-B:C fire extinguisher within 30 feet of cooking equipment and a Class K fire extinguisher for deep fat fryers.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 907.20.1 Fire Alarm shall be maintained in operating condition.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19 CCR § 904 Fire Suppression systems shall be in operating condition (Inspected/Service Qtrly; Recertified every 5 years).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 903.4 Sprinkler systems with 20 heads or more shall be electronically supervised.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Commercial cooking equipment producing grease laden vapors shall be provided with an automatic fire extinguishing system.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 904.11	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 508.5.4 Fire hydrants and other fire protection equipment shall not be obstructed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 904.11.6.4 Service automatic fire-extinguishing systems every 6 months, and after activation of the system.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ELECTRICAL REQUIREMENTS

CFC 605.5 Extension cords and flexible cords shall not be used as a substitute for permanent wiring.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.5.3 Appliance cords maintained in good condition without splices, deterioration, or damage.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.3 Provide a minimum clearance of 30" wide, 36" deep, and 78" from face of electrical switchboards and panel boards.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.3.1 Clearly identify electrical rooms with signage and label all disconnecting means, feeder/branch circuits.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CFC 605.6 Open junction boxes and open-wiring splices shall be provided with approved electrical outlet/switch covers.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

PERMITS

105.6.34 Obtain Public Assembly Permit from Fire Prevention	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
105.6.32 Obtain Open Flame Permit for Candles/Open flame in Public Assembly occupancies from Fire Prevention	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
105.6.22 Obtain Permit for High-Piled Storage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

MISCELLANEOUS REQUIREMENTS

OMC 5.04.040 Valid City of Oakland Business Tax Certificate	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CCR 2729.1(a) Provide/Obtain a current Hazardous Materials Business Plan (HMBP)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

In accordance with the California Fire Code Section 104.5 you are hereby ordered to correct all violations marked N/C immediately upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court, plus additional fees and civil penalties. An inspection to determine if you have complied with this order will be conducted on or about ____/____/____. An inspection fee will be invoiced at a later date in accordance with the City's Master Fee Schedule. If you have questions, contact the inspector above at phone number _____.

Date: 09/23/14 Owner/Mgr (Signature) [Signature] Owner/Mgr (Print) Todd Connors

Distribution: White (FPB) Yellow (Owner/Manager) Pink (Fire Station)



OAKLAND FIRE DEPARTMENT INSPECTION RECORD



BT ☐

B

Block # 1099 Bus Lic. # 1012568

ADDRESS: 4444 TELEGRAPH

BUSINESS NAME: PENT-A RELIC

MANAGER/OWNER: Barry P. Reed

PHONE #: 601-6560

FAX #:

☒ A reasonable degree of fire safety exists at this time

(Date) 2/23/07

(Inspector Number)

☐ In accordance with Section 103.4.3.1 of the California Fire Code, you are hereby ordered to correct all violations immediately upon receipt of this notice. Failure to comply with this lawful order may result in a citation to appear in Municipal Court.

Group B occupancies shall include the use of office, professional or service-type transactions. Such occupancies including eating and drinking establishments with an occupant load of less than 50.

OCCUPANCY DESCRIPTION Car Lot

1st 2nd 3rd OK

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

GENERAL SAFETY REQUIREMENTS

- 019 Provide address numbers plainly visible and legible from the street and of contrasting color to their background.
- B-3C Keep dumpsters 5 feet from combustible walls, openings, and combustible roof eave lines.
- B-5A Flammable and combustible liquids not exceeding 10 gallons are allowed to be used for maintenance purposes and operation of equipment.
- B-3B Storage not permitted in boiler rooms, mechanical rooms, electrical panel rooms.
- S-6G Maintain a minimum of 18" from ceilings of sprinklered building or 24" from ceilings in non-sprinklered building. (ex. along walls)
- B-5B Combustibles are to be kept a minimum of 18" from heating appliances.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

EXITING AND CONSTRUCTION REQUIREMENTS

- B-2A Obstructions to exits shall not be placed in the required width, and exits shall not be obstructed in any manner.
- S-5H All locking devices shall be of an approved type.
- B-2B Exit doors shall be maintained in an operable condition at all times.
- B-2D Exit paths shall be illuminated when the building or structure is occupied.
- B-2I Exit signs shall be installed at required exits and where otherwise necessary to clearly indicate direction of egress.
- B-2G When the exit way is not easily identified, additional exit signs may be required.
- B-2E Exit signs shall be internally or externally illuminated by two lamps or shall be of the self-luminous type.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

FIRE PROTECTION EQUIPMENT

- C-1B Fire assemblies shall be maintained in working condition.
- B-1A Minimum of one 2-A:10-B:C extinguisher shall be easily accessible so that travel distance does not exceed 75'. Extinguishers shall be mounted in plain view with top between 3'-5' from the floor.
- B-1D Extinguishers shall be serviced annually and shall have a current servicing tag attached.
- A2-1C A 40-B:C extinguisher shall be provided in all kitchens with 30'. (K-type extinguisher required for deep-fat fryers.)
- B-6C Where an automatic or manual fire alarm system is in place, such system shall be maintained in operating condition.
- B-6D Where an automatic extinguishing system is in place, such systems shall be serviced and maintained in operating condition. (Inspected/serviced quarterly; re-certified every 5 years for fire sprinklers.)
- 041 All fire sprinkler systems over 100 heads shall be continuously monitored by a UL listed monitoring company.
- 035 Provide fire sprinkler coverage to all areas of the building. Plans and/or permits (may/will) be required.
- B-6B Fire hydrants and other fire protection equipment shall not be obstructed and shall be maintained in an operative condition.
- 059 Maintain required service records for: automatic extinguishing system (min. 6 months), commercial hoods, ducts, filters.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

ELECTRICAL REQUIREMENTS

- B-4B Extension cords shall not be used as a substitute for permanent wiring.
- B-4C Appliance cords shall be kept in good condition with no splices.
- B-4D A clear depth of 30" and a height of 78" shall be maintained from the face of electrical switchboards and panel boards.
- B-4D Electrical main control panels and sub-panels shall be labeled as to the area served.
- B-4D Doors into electrical control rooms shall be marked with a plainly visible/legible sign, "ELECTRICAL ROOM."
- B-4C Repair, replace, correct electrical hazards of wiring, outlets, cover plates, circuit breakers and other devices.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

PERMITS ARE REQUIRED OR COMPLIANCE WITH POSTED PERMIT

- P-C.7 To store, use, or handle compressed gases.
- P-F.3 To store, handle, or use flammable or combustible liquids.
- P-H.1 To store, transport, dispense, use, or handle hazardous materials.
- P-RZ For Hot-work operations including the use of welding, cutting, or other hot-work equipment.
- To use candles / open flames in an assembly.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

MISC. REQUIREMENTS

- S-6E Racks with storage over 8' high must be installed with a building permit and engineered securing system.

☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒
☐ ☐ ☐ ☒

An inspection to determine if you have complied with this order will be conducted on or about ____/____/____. If you have further questions, contact the undersigned Inspector at phone number: _____.

1st Insp. 2,2307

Owner/Mgr. JTL

Inspector (print) Hille Sheim

2nd Insp. / /

Owner/Mgr.

Inspector (print)

3rd Insp. / /

Owner/Mgr.

Inspector (print)